

Dynamic Disturbance Recording (DDR)

[Return to Glossary](#)

Dynamic Disturbance Recording (DDR) involves capturing incidents that represent behaviour of the power system during dynamic events, such as low frequency oscillations, abnormal under/over frequency, voltage excursions and system's wide transients.

DDR can be used for wide-area disturbance monitoring to analyse the system's transient and post-transient response and predict system model [performance](#).

Source: [Dynamic Disturbance Recording \(DDR\)](#)

From:
<https://www.omgwiki.org/ddsf/> - **DDS Foundation Wiki**

Permanent link:
https://www.omgwiki.org/ddsf/doku.php?id=ddsf:public:guidebook:06_append:glossary:d:ddr&rev=1626291823

Last update: **2021/07/14 15:43**

