

IEC 62541-009 OPC Unified Architecture - Part 9: Alarms and Conditions

[return to the IEC Standards](#)

Table 1: Data sheet for OPC Unified Architecture - Part 9: Alarms and Conditions

Title	OPC Unified Architecture - Part 9: Alarms and Conditions
Version	2020
Document Number	62541-9
Release Date	2020
Reference	https://webstore.iec.ch/publication/61118

Note: The following is an excerpt from the official IEC catalog. It is provided here as a convenience and is not authoritative. Refer to the original document as the authoritative reference.

Abstract

IEC 62541-9:2020 specifies the representation of Alarms and Conditions in the OPC Unified Architecture. Included is the Information Model representation of Alarms and Conditions in the OPC UA address space. Other aspects of alarm systems such as alarm philosophy, life cycle, alarm response times, alarm types and many other details are captured in documents such as IEC 62682 and ISA 18.2. The Alarms and Conditions Information Model in this specification is designed in accordance with IEC 62682 and ISA 18.2.

This third edition cancels and replaces the second edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) added optional engineering units to the definition of **RateOfChange** alarms
- b) to fulfill the IEC 62682 model, the following elements have been added:

- **AlarmConditionType** States:

- **Suppression**
- **Silence**
- **OutOfService**
- **Latched**

- 2. **AlarmConditionType** Properties:

- **OnDelay**
- **OffDelay**
- **FirstInGroup**
- **ReAlarmTime**

- 3. New alarm types:

- **DiscrepancyAlarm**
 - **DeviationAlarm**
 - **InstrumentDiagnosticAlarm**
 - **SystemDiagnosticAlarm**
- c) added Annex that specifies how the concepts of this OPC UA part maps to IEC 62682 and ISA 18.2;
- d) added new **ConditionClasses**:
- **Safety**
 - **HighlyManaged**
 - **Statistical**
 - **Testing**
 - **Training**
- e) added **CertificateExpiration AlarmType**
- f) added Alarm Metrics model

From:
<https://www.omgwiki.org/dido/> - **DIDO Wiki**

Permanent link:
https://www.omgwiki.org/dido/doku.php?id=dido:public:ra:xapend:xapend.b_stds:tech:iec:62541-9&rev=1642193791

Last update: 2022/01/14 15:56

